



LABORATORY ANALYTICAL REPORT

INTERTEK REF.:	BakWL 0462/19
REVISION #:	0
DATE:	05.04.2019

FOR THE ATTENTION OF:

Narmina Zeynalova

Kristal Ltd.

Baku, Azerbaijan

CB1148





1.0 Sample Information

REFERENCE NUMBER:	BakWL 0462/19
GRADE OF PRODUCT:	Drinking water
DATE OF FILLING:	27.03.19
SAMPLING POINT/PLACE:	"Ipek Su", opened bottled water
ENTRY DATE:	04.04.19
CONTAINER TYPE:	Open plastic bottle
VOLUME:	19 L
NOTES:	

2.0 TESTING DETAILS

2.1 General Information

Date of testing:	04.04.19-05.04.19
Performed by:	Rita Babayeva
Testing Laboratory:	WTR, Baku laboratory
Notes:	-

2.2 Results of analysis

BakWL 0462/19

Microbiological analyses

N	Test	Specification	Result
1	Total Coliforms	0 per 100 ml	0
2	E-coli	0 per 100 ml	0

The enumeration of total Coliform bacteria and E Coli.

Principle of method

Colilert-18, Quanti Tray MPN method is used for the detection of coliforms and E Coli in drinking water by color changing and to fluorescence for E Coli.



3.0 QC STATEMENT

1. Intertek Azeri Ltd holds ISO 9001 Quality Management System.
2. Intertek Azeri Ltd procedures are accredited by Azerbaijan Accreditation Center Public Entity (AZS ISO/IEC 17025:2009).
3. Results related only to the items tested on samples submitted/drawn by Intertek Azeri Ltd. Laboratories.
4. This report shall not be reproduced in full or in part without written authorization of Intertek Azeri Ltd.
5. Uncertainty of measurements is made for the tests and will be provided upon request.

4.0 VALIDATION

The report is prepared by: Rita Babayeva

The report has been verified and approved by: Esmira Babayeva

Date of approval: 05.04.19

Signature:



This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Only the Client is authorized to permit copying or distribution of this report and only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and/or test results relate only to the samples/items tested/inspected. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



5.0 CONTACT DETAILS

**BUSINESS MATTERS
GENERAL
MANAGEMENT** Elkhan Hajiyeu – Director
elkhan.hajiyeu@intertek.com
+99412 4480627 (ext. 111)

**TECHNICAL
QUESTIONS:
(TESTING/SAMPLING)** Esmira Babayeva – Lab Supervisor
esmira.babayeva@intertek.com
+99412 4480627 (ext. 107)

INTERTEK AZERI LTD. WWW.INTERTEK.COM	
Main Laboratory Official Address AZ1026, Azerbaijan Republic, Baku International Sea Port, Cargo Terminal #2, Mirza Davud Street 2236	Legal Address of Intertek Azeri ltd. AZ1026, Azerbaijan Republic, Baku Khatai district, 2236 Mirza Davud Huseynov Str

6.0 REVISION HISTORY

REV NO	REVISION DATE	REVISION DETAILS	AUTHOR	ISSUED BY