



## LABORATORY ANALYTICAL REPORT

INTERTEK REF.:	BakWL 1285/18
REVISION #:	0
DATE:	01.10.18

FOR THE ATTENTION OF:

*Rasim Babayev*

*Kristal Ltd.*

*Baku, Azerbaijan*

**CB1148**



## 1.0 Sample Information

REFERENCE NUMBER:	BakWL 1285/18
GRADE OF PRODUCT:	Drinking water
SAMPLING POINT/PLACE:	"Ipek Su" bottled water
ENTRY DATE:	27.09.18
CONTAINER TYPE:	Plastic bottle
VOLUME:	19 L
NOTES:	

## 2.0 TESTING DETAILS

### 2.1 General Information

Date of testing:	27.09.18-29.09.18
Performed by:	Rita Babayeva
Testing Laboratory:	WTR, Baku laboratory
Notes:	-

### 2.2 Results of analysis

#### BakWL 1285/18

#### Microbiological analyses

N	Test	Specification	Result
1	Total Coliforms	0 per 100 ml	0
2	E-coli	0 per 100 ml	0
3	TVC at 22 °C	< 100 Counts per ml	0
4	TVC at 37 °C	< 10 Counts per ml	0

#### The enumeration of total Coliform bacteria and E Coli.

##### Principle of method

Colilert-18, Quanti Tray MPN method is used for the detection of coliforms and E Coli in drinking water by color changing and to fluorescence for E Coli.

#### Total Viable Count bacteria at 22°C and at 37°C content.

##### Principle of method

Viable bacteria counted by the pour plate method with yeast extract agar.



### 3.0 QC STATEMENT

1. Intertek Azeri Ltd holds ISO 9001 Quality Management System.
2. Intertek Azeri Ltd procedures are accredited by Azerbaijan Republic State Agency for Standardization, Metrology and Patents (AZStandard).
3. Results related only to the items tested on samples submitted/drawn by Intertek Azeri Ltd. Laboratories.
4. This report shall not be reproduced in full or in part without written authorization of Intertek Azeri Ltd.
5. Uncertainty of measurements is made for the tests and will be provided upon request.

### 4.0 VALIDATION

The report is prepared by: Rita Babayeva

The report has been verified and approved by: Esmira Babayeva

Date of approval: 01.10.18

Signature:

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Only the Client is authorized to permit copying or distribution of this report and only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and/or test results relate only to the samples/items tested/inspected. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



## 5.0 CONTACT DETAILS

**BUSINESS MATTERS GENERAL MANAGEMENT** Elkhan Hajiyev – Director  
[elkhan.hajiyev@intertek.com](mailto:elkhan.hajiyev@intertek.com)  
+99412 4480627 (ext. 111)

**TECHNICAL QUESTIONS: (TESTING/SAMPLING)** Esmira Babayeva – Lab Supervisor  
[esmira.babayeva@intertek.com](mailto:esmira.babayeva@intertek.com)  
+99412 4480627 (ext. 106)

<b>INTERTEK AZERI LTD.</b> <a href="http://WWW.INTERTEK.COM">WWW.INTERTEK.COM</a>	
<b>Main Laboratory Official Address</b> AZ1026, Azerbaijan Republic, Baku International Sea Port, Cargo Terminal #2, Mirza Davud Street 2236	<b>Legal Address of Intertek Azeri ltd.</b> AZ1026, Azerbaijan Republic, Baku Khatai district, 2236 Mirza Davud Huseynov Str

## 6.0 REVISION HISTORY

<b>REV NO</b>	<b>REVISION DATE</b>	<b>REVISION DETAILS</b>	<b>AUTHOR</b>	<b>ISSUED BY</b>